Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CF900

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: EDDY BRUSS		Phone #: (715)349-7357
Mailing Address: 25044 WALBERG RD		
City: WEBSTER	State: WI	Zip Code: 54893
County: Burnett	Co. Permit #:	Notification #:
Completed: 05-12-1992		

Well Constructor (Business Name): BEECROFT, GARY	Lic. #: 137	Facility ID # (Public Wells):
Address: 1318 350TH AVE SIREN WI 54872-9604		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.2

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of MEENON
Fire # (if avail.): 25044
Street Address or Road Name and Number
Subdivision Name | Lot # | Block #
Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code
SE NE or Govt Lot # | Section: 35 | Township: 39 N | Range: 16 W

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
DRIVE POINT HAS POOR WATE
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	84.5

Upper Enlarged Drillhole
Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	12
		C	M	SILTY SANDY DLAY	12	25
		S		SAND	25	52
		Y	U	MUDDY SAND @ GRAVEL	52	69
		P		HARD PAN	69	78
	A	G		COARSE GRAVEL	78	84.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL 18.97# PER FT ASTM A53 .280 WALLTHICKNESS SAWHILL PIPE CO. WELDED JOINTS	Surface	84.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GRANUELS WHILE DRIVI	Surface	0	

9. Static Water Level
8 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 10 GP for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
OWNER WILL SEAL

13. Constructor / Supervisory Driller	Lic #	Date Signed
GB		05-25-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
GB		05-25-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		71

Type	Qualifier	Distance
Building Overhang		6
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 06-09-1992 Updated On: 06-09-1992 Review Status: