

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CG297		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner D G HARDING						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 11351 LONDON DERRY						Town of FLORENCE						W440									
City ROMEO						State MI		Zip Code 48065				Street Address or Road Name and Number TALL PINES RD									
County Florence		Co. Permit #		Notification #		Completed 05-28-1991		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) KLEIMAN PUMP AND WELLDRIILLING IN				Lic. # 575		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address P O BOX 704 IRON MOUNTAIN MI 49801				Well Plan Approval #		NW SE		Section 32		Township 40 N		Range 19 E		or Govt Lot #							
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0.8				2. Well Type Replacement									
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ? OLD WELL SLOW				Construction Type Drilled											
3. Well serves 1 # of				Private, potable		Heat Exchange ___ # of drillholes				4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		41		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Q S G		FINE SAND W/GRAVEL CAVING		Surface		15					
6		NEW A-53 BLK STL. PE. .280" WALL 18.97#/FT TIAWAN		Surface		39		Q G		GRAVEL-CAVING		15		25							
6		NEW A-53 BLK STL. PE. .280" WALL 18.97#/FT TIAWAN		Surface		39		Q S		FINE SAND-CAVING		25		33							
5		JOHNSON SS WW FIG K PKR. BB 22 SLOT		39		41		A S		COARSE CLEAN SAND		33		41							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		21 ft. below ground surface				18 in. above grade							
6		NEW A-53 BLK STL. PE. .280" WALL 18.97#/FT TIAWAN				Surface		39		Pumping level 40 ft. below surface				Developed ? Yes							
6		NEW A-53 BLK STL. PE. .280" WALL 18.97#/FT TIAWAN				Surface		39		Pumping at 15 GP for 0.5 Hrs.				Disinfected ? Yes							
5		JOHNSON SS WW FIG K PKR. BB 22 SLOT				39		41		Pumping Method ?				Capped ? Yes							
7. Grout or Other Sealing Material Method														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
13. Constructor / Supervisory Driller										Lic #		Date Signed									
HPK										03-04-1991		Drill Rig Operator									
DN										02-28-1991		Lic or Reg #									
02-28-1991										Date Signed		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Shoreline/Pool		300
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 07-12-1991

Updated On: 07-12-1991

Review Status: