Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CG298

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JEFF KEGLY			Phone #
Mailing Address: MONTGOMERY LAKE RD			
City: SPREAD EAGLE	State: WI	Zip Code: 54121	
County: Florence	Co. Permit #	Notification #	Completed: 12-13-1990

Well Constructor (Business Name): KLEIMAN PUMP AND WELLDRILLING IN	Lic. #: 575	Facility ID # (Public Wells)
Address: P O BOX 704 IRON MOUNTAIN MI 49801		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.4

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of FLORENCE

Fire # (if avail.)

Street Address or Road Name and Number: MONTGOMERY LAKE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

SE NE or Govt Lot #	Section: 31	Township: 40 N	Range: 19 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	102

Upper Enlarged Drillhole
Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Q	S	G	SAND @ GRAVEL, CAVING, CLEAN BROWN	Surface	40
S	Q		SOFT, BROKEN BLACK SLATEROCK, CAVING	10	70
Q	S		SAND, CAVING, BROWN, CLEAN	40	60
H	Q		FIRM, BLACK, SLATE ROCK	70	102

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL A53 18.97#PER FL P.E.	Surface	73
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

9. Static Water Level
54 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 20 GP for 1 Hrs.
Pumping Method ?

11. Well Is
22 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
HPK		03-04-1991
Drill Rig Operator	Lic or Reg #	Date Signed
DN		12-14-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Landfill		2500

Comment:

Created On: 07-15-1991 Updated On: 07-15-1991 Review Status: