Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CG673

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FLORIAN D EASPAMER	Phone #: (414)688-2819
Mailing Address: W6723 N EASTWOOD	
City: VAN DYNE	State: WI Zip Code: 54979
County: Fond du Lac	Co. Permit #:
Notification #:	Completed: 02-07-1991
Well Constructor (Business Name): KEIFENHEIM HOWARD E	Lic. #: 251
Facility ID # (Public Wells):	
Address: RT 1 N8248 MOUNT CALVARY WI 53057	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.4	

1. Well Location

Town of FRIENDSHIP	Fire # (if avail.):
Street Address or Road Name and Number: NORTH EASTWOOD DR	
Subdivision Name:	Lot #: Block #:
Latitude / Longitude in Decimal Degree (DD): 43.88747 °N -88.49505 °W	Method Code: GPS008
SE NW or Govt Lot #:	Section: 5 Township: 16 N Range: 17 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	80

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		C		RED CLAY	Surface	29
G		C		GRAY CLAY	29	37
G		C	S	SANDY GRAY CLAY	37	42
		L		SHELL ROCK	42	43
		L		LIMESTONE	43	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18:97 P.E. A.S.T.M. A-53-B WELDED SAW HILLSTEEL CORP.	Surface	43
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

4 ft. below ground surface

10. Pump Test

Pumping level 18 ft. below surface

Pumping at 20 GP for 2 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
RED CLAY MUD SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
HK		02-10-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SDK		02-10-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		20	Other Contamination Sources		59
			Sewer - Building Sanitary		36

Comment:

Created On: 07-17-1991 Updated On: 08-17-2022 Review Status: