# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* CG674

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | |
|---|---|
| Property Owner: DALE KRAUD | Phone #: (414)795-4529 |
| Mailing Address: N8061 CHURCH RD | |
| City: MALINE | State: WI — Zip Code: 53049 |
| County: Fond du Lac | Co. Permit #: — Notification #: — Completed: 02-01-1991 |
| Well Constructor (Business Name): KEIFENHEIM HOWARD E | Lic. #: 251 — Facility ID # (Public Wells): |
| Address: RT 1 N8248 MOUNT CALVARY WI 53057 | Well Plan Approval #: — Approval Date (mm-dd-yyyy): |
| Hicap Permanent Well #: | Common Well #: — Specific Capacity: 0.8 |

**1. Well Location**

| | |
|---|---|
| Town of TAYCHEDAH | Fire # (if avail.): N8061 |
| Street Address or Road Name and Number: CHURCH RD | |
| Subdivision Name: | Lot #: — Block #: |
| Latitude / Longitude in Decimal Degree (DD): 43.8325 °N -88.3415 °W | Method Code: GCD013 |
| NE NE or Govt Lot #: | Section: 28 — Township: 16 N — Range: 18 E |

**2. Well Type** Reconstruction

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: OLD WELL GOING DRY

Construction Type: Drilled

**3. Well serves** 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 6 | Surface | 240 |

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

**8. Geology**

| Geology Codes | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|
| L | LIMESTONE | Surface | 203 |
| H | SHALE | 203 | 240 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
|---|---|---|---|
| | | | |

**7. Grout or Other Sealing Material**

Method

**9. Static Water Level**

80 ft. below ground surface

**10. Pump Test**

Pumping level 92 ft. below surface

Pumping at 10 GP for 2 Hrs.

Pumping Method ?

**11. Well Is**

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

**12.** Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| HK | | |
| **Drill Rig Operator** | **Lic or Reg #** | **Date Signed** |
| SDK | | 02-10-1991 |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| POWTS dispersal component (soil absorption unit or mound) | | 59 | Downspout/Yard Hydrant | | 13 |
| Building Overhang | | 2 | Septic or Holding, or POWTS Tank | | 36 |

Comment: ORIGINAL WELL DRILLED BY CLEM WAGNER TO 128'

Created On: 07-17-1991 Updated On: 10-08-2019 Review Status: