

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CG674		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner DALE KRAUD						Phone # (414)795-4529		1. Well Location				Fire # (if avail.)							
Mailing Address N8061 CHURCH RD						Town of TAYCHEDAH						N8061							
City MALINE						State WI		Zip Code 53049				Street Address or Road Name and Number CHURCH RD							
County Fond du Lac		Co. Permit #		Notification #		Completed 02-01-1991		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) KEIFENHEIM HOWARD E				Lic. # 251		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.8325 °N -88.3415 °W				Method Code GCD013					
Address RT 1 N8248 MOUNT CALVARY WI 53057				Well Plan Approval #		NE NE		Section 28		Township 16 N		Range 18 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.8		2. Well Type Reconstruction of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD WELL GOING DRY													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.) 6		From (ft.) Surface		To (ft.) 240		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
						Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				L LIMESTONE H SHALE				Surface 203 203 240					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		80 ft. below ground surface				20 in. above grade					
7. Grout or Other Sealing Material Method												10. Pump Test Pumping level 92 ft. below surface Pumping at 10 GP for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												HK							
												Drill Rig Operator				Lic or Reg #		Date Signed	
						02-10-1991													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		2	POWTS dispersal component (soil absorption unit or mound)		59
Septic or Holding, or POWTS Tank		36	Downspout/Yard Hydrant		13

Comment: ORIGINAL WELL DRILLED BY CLEM WAGNER TO 128'

Created On: 07-17-1991

Updated On: 10-08-2019

Review Status: