Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CH045

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MID WIS HOMES-HANNEMAN			Phone #: (715)258-3591
Mailing Address: 715 W HILL ST			
City: WAUPACA	State: WI	Zip Code: 54981	
County: Portage	Co. Permit #:	Notification #:	Completed: 01-16-1990

Well Constructor (Business Name): MAVES LEONARD K	Lic. #: 190	Facility ID # (Public Wells):	
Address: 4347 KUBISIAK DR AMHERST WI 54406		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of AMHERST
Fire # (if avail.)
Street Address or Road Name and Number: 8742 EDGEWATER DR - AMHERST JUNCTION

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 44.4688 °N -89.3448 °W
Method Code: GCD013

SW NW or Govt Lot #	Section: 18	Township: 23 N	Range: 10 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
NEW HOUSE
Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	73

Upper Enlarged Drillhole / Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Q	S	G	SAND @ GRAVEL C BR SOFT	Surface	25
V	C		CLAY NL GRAY SOFT	25	63
Q	S	G	SAND @ GRAVEL C BR SOFT	63	73

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL MERCER TANDL A589 11.00# FT	Surface	69
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	X4X15 SLOT STAINLESS SCREEN	69	73

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 15 GP for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LM		01-05-1990
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Overhang		7
Shoreline/Pool		65
Sewer - Building Sanitary		25
Septic or Holding, or POWTS Tank		39

Comment:

Created On: 05-17-1990 Updated On: 05-07-2020 Review Status: