

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CH048		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner PETE BLENKER						Phone # () 829-5665		1. Well Location				Fire # (if avail.)							
Mailing Address 237 SOO LINE STA						Town of AMHERST						Street Address or Road Name and Number YELLOW BRICK RD							
City AMHERST				State WI		Zip Code 54406													
County		Co. Permit #		Notification #		Completed 03-21-1990		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) MAVES LEONARD K				Lic. # 190		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 4347 KUBISIAK DR AMHERST WI 54406				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 15 23 N 10 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOUSE											
Approval Date (mm-dd-yyyy)				Specific Capacity 2.5															
Hicap Permanent Well #				Common Well #		Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		133		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		Q S G SAND @ GRAVEL C BR SOFT Q S FINE SAND C BR SOFT Q S G SAND @ GRAVEL C BR SOFT Q S FINE SAND C BR SOFT Q S G SAND @ GRAVEL C BR SOFT		Surface 63 63 90 90 110 110 128 128 133									
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		100 ft. below ground surface				12 in. above grade					
6		NEW BL STEEL WELDED NEWPORT ASTM A53 18.97LB FT1780 LB TEST				Surface		129		10. Pump Test Pumping level 112 ft. below surface Pumping at 30 GP for 24 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
6		X4'X15 SLOT STAINLESS STEEL				129		133											
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												LM						03-23-1990	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		7	Sewer - Building Sanitary		30

Comment:

Created On: 05-17-1990

Updated On: 05-17-1990

Review Status: