Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CH048

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PETE BLENKER			Phone #: ( )829-5665
Mailing Address: 237 SOO LINE STA			
City: AMHERST	State: WI	Zip Code: 54406	
County: Portage	Co. Permit #:	Notification #:	Completed: 03-21-1990

Well Constructor (Business Name): MAVES LEONARD K	Lic. #: 190	Facility ID # (Public Wells):	
Address: 4347 KUBISIAK DR AMHERST WI 54406		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.5	

1. Well Location

Town of AMHERST

Fire # (if avail.):

Street Address or Road Name and Number: YELLOW BRICK RD

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
SW SE or Govt Lot #:	Section: 15	Township: 23 N	Range: 10 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: NEW HOUSE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	133

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Q	S	G	SAND @ GRAVEL C BR SOFT	Surface	63
Q	S		FINE SAND C BR SOFT	63	90
Q	S	G	SAND @ GRAVEL C BR SOFT	90	110
Q	S		FINE SAND C BR SOFT	110	128
Q	S	G	SAND @ GRAVEL C BR SOFT	128	133

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BL STEEL WELDED NEWPORT ASTM A53 18.97LB FT1780 LB TEST	Surface	129
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	X4'X15 SLOT STAINLESS STEEL	129	133

9. Static Water Level

100 ft. below ground surface

10. Pump Test

Pumping level 112 ft. below surface

Pumping at 30 GP for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LM		03-23-1990
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		7	Sewer - Building Sanitary		30

Comment:

Created On: 05-17-1990 Updated On: 05-17-1990 Review Status: