Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CH399

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ARNOLD SKIBBA			Phone #: (715)457-6799
Mailing Address:			
City: JUNCTION CITY	State: WI	Zip Code: 54443	
County: Portage	Co. Permit #:	Notification #:	Completed: 05-04-1992

Well Constructor (Business Name): HEEG, BRIAN	Lic. #: 355	Facility ID # (Public Wells):	
Address: 5069 E CTY F AUBURNDALE WI 54412		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of EAU PLEINE

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

NE SE or Govt Lot #:	Section: 22	Township: 25 N	Range: 6 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
HOUSE

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	47
6	47	173

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 9in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	10
	S	Q	C	SOFT GRANITE WITH CLAY LAYERS	10	46
		Q		GRANITE	46	173

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ST STEEL ASTM A53B SAWHILL USA WELDED JOINT	Surface	47
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method PUMP

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	47	8

9. Static Water Level
6 ft. below ground surface

10. Pump Test
Pumping level 160 ft. below surface
Pumping at 4.5 GP for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
BH		06-12-1992
Drill Rig Operator	Lic or Reg #	Date Signed
BH		06-12-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture		1 GPM BEFORE 4.5 AFTR PAKRS 70 100 125'PRESSURES 650-450 1150-550 1600-1200

Created On: 06-29-1992 Updated On: 10-15-2026 Review Status: