

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CH399		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner ARNOLD SKIBBA						Phone # (715)457-6799		1. Well Location				Fire # (if avail.)					
Mailing Address						Town of EAU PLEINE						Street Address or Road Name and Number					
City JUNCTION CITY				State WI		Zip Code 54443											
County		Co. Permit #		Notification #		Completed 05-04-1992		Subdivision Name			Lot #		Block #				
Portage		Well Constructor (Business Name) HEEG, BRIAN		Lic. # 355		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code						
Address 5069 E CTY F AUBURNDAL WI 54412				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 22 25 N 6 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? HOUSE									
Hicap Permanent Well #		Common Well #		Specific Capacity		Construction Type Drilled											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		4. Potential Contamination Sources - ON REVERSE SIDE									
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		47		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 9in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)		C CLAY S Q C SOFT GRANITE WITH CLAY LAYERS Q GRANITE		Surface 10 10 46 46 173		10 46 173					
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		6 ft. below ground surface				18 in. above grade			
6		ST STEEL ASTM A53B SAWHILL USA WELDED JOINT				Surface		47		10. Pump Test Pumping level 160 ft. below surface Pumping at 4.5 GP for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?											
Method PUMP						Filled & Sealed Well(s) as needed? NONE											
Kind of Sealing Material		From (ft.)		To (ft.)												# Sacks Cement	
CEMENT		Surface		47		8		13. Constructor / Supervisory Driller				Lic #		Date Signed			
						BH						06-12-1992					
						Drill Rig Operator				Lic or Reg #		Date Signed					
						BH						06-12-1992					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture		1 GPM BEFORE 4.5 AFTR PAKRS 70 100 125'PRESSURES 650-450 1150-550 1600-1200

Created On: 06-29-1992

Updated On: 06-29-1992

Review Status: