

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CH896		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner BILL MELTON						Phone #		1. Well Location				Fire # (if avail.)													
Mailing Address N2885 LIETZOW RD						Town of PESHTIGO						N2885													
City MARINETTE						State WI		Zip Code 54143				Street Address or Road Name and Number N2885 LIETZOW RD													
County Marinette		Co. Permit #		Notification #		Completed 03-17-1992		Subdivision Name				Lot #		Block #											
Well Constructor (Business Name) JOHNSON, GREGORY L				Lic. # 625		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code													
Address N3719 LOUCKS RD PESHTIGO WI 54157-9750				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W		NW		NW		Section		Township		Range					
Hicap Permanent Well #				Common Well #		Specific Capacity 5		or Govt Lot #		23		30 N		23		E		2. Well Type New Well		of previous unique well #		constructed in			
3. Well serves 1 # of Private, potable						Hicap Well ? No		Reason for replaced or reconstructed well ?																	
Heat Exchange ___ # of drillholes						Hicap Property ? No		Construction Type Drilled																	
4. Potential Contamination Sources - ON REVERSE SIDE						5. Drillhole Dimensions and Construction Method						8. Geology													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
10		Surface		8		Rotary - Mud Circulation		Rotary - Air		Rotary - Air & Foam		Drill-Through Casing Hammer		Reverse Rotary		Cable-tool Bit 10in. dia...		Dual Rotary		Temp. Outer Casing 8in. dia		Removed? ___ depth ft. (If NO explain on back side)			
6		8		50		Yes		Yes		Yes		S		SAND		Surface		30							
6		8		50		Yes		Yes		Yes		Z		CLAY @ GRAVEL		30		40							
6		8		50		Yes		Yes		Yes		L		LIME ROCK		40		50							
6. Casing, Liner, Screen						9. Static Water Level						11. Well Is													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10 ft. below ground surface						12 in. above grade									
6		ASTM-53-A V.S.P. CO. 1780 P.S.I. THREADED @COUPLED				Surface		41		10. Pump Test						Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 12 ft. below surface						Disinfected ? Yes									
6		6				6		6		Pumping at 10 GP for 16 Hrs.						Capped ? Yes									
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?						Filled & Sealed Well(s) as needed?													
Method						13. Constructor / Supervisory Driller						Lic #						Date Signed							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		GJ						03-21-1992											
PUDDLED CLAY		Surface		8		8		Drill Rig Operator						Lic or Reg #						Date Signed					
PUDDLED CLAY		Surface		8		8		03-21-1992						03-21-1992											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Foundation Drain to Clearwater		16
Building Overhang		12	Sewer - Building Sanitary		50
Clearwater Sump		20	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 04-23-1992

Updated On: 04-23-1992

Review Status: