Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CH900

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MARTHA WALK			Phone #
Mailing Address: W5921 CTY TK B			
City: PESHTIGO	State: WI	Zip Code: 54157	
County: Marinette	Co. Permit #	Notification #	Completed: 05-31-1992

Well Constructor (Business Name): JOHNSON, GREGORY L	Lic. #: 625	Facility ID # (Public Wells)	
Address: N3719 LOUCKS RD PESHTIGO WI 54157-9750		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of GROVE

Fire # (if avail.): W5921

Street Address or Road Name and Number: W5921 CTY TK B

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 45.0623 °N -87.8943 °W
Method Code: GCD013

NW	NE	Section	Township	Range
or Govt Lot #		24	30 N	21 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
8	20	41
6	41	55

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 8in. dia...
Dual Rotary .....
Yes Temp. Outer Casing 8in. dia
Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	26
L	LIMEROCK	26	52
N	SAND STONE	52	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM-53-A V.S.P. CO 1780 P.S.I. PLAIN END	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 10 GP for 17 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method PUMP IN

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CLAY	Surface	8	
CEMENT	8	41	12

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GJ		06-05-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Sewer - Building Sanitary		30
Building Overhang		25	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-24-1992 Updated On: 10-22-2019 Review Status: