

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CH900		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MARTHA WALK						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address W5921 CTY TK B						Town of GROVE						W5921			
City PESHTIGO						State WI		Zip Code 54157				Street Address or Road Name and Number W5921 CTY TK B			
County Marinette		Co. Permit #		Notification #		Completed 05-31-1992		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) JOHNSON, GREGORY L				Lic. # 625		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.0623 °N -87.8943 °W				Method Code GCD013	
Address N3719 LOUCKS RD PESHTIGO WI 54157-9750				Well Plan Approval #				NW NE Section Township Range or Govt Lot # 24 30 N 21 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ?					
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #				Common Well #		Specific Capacity 1				Construction Type Drilled					
3. Well serves 1 # of Private, potable				Hicap Well ? No Hicap Property ? No											
Heat Exchange ____ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 20			Rotary - Mud Circulation												
8 20 41			Rotary - Air												
6 41 55			Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 8in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? ____depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
C				CLAY				Surface		26					
L				LIMEROCK				26		52					
N				SAND STONE				52		55					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		ASTM-53-A V.S.P. CO 1780 P.S.I. PLAIN END				Surface		42							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material		Method PUMP IN				Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement			
PUDDLED CLAY		Surface				8		8		41		12			
CEMENT		8				41		12		12		12			
9. Static Water Level															
25 ft. below ground surface															
10. Pump Test															
Pumping level 35 ft. below surface															
Pumping at 10 GP for 17 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
GJ								Lic #		Date Signed 06-05-1992					
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Sewer - Building Sanitary		30
Building Overhang		25	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 06-24-1992

Updated On: 10-22-2019

Review Status: