Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CK100

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: DONALD DILWORTH	Phone #: (414)554-1913
Mailing Address: 3251 DEBRA LN	
City: RACINE	State: WI — Zip Code: 53403
County: Adams	Co. Permit #: — Notification #: — Completed: 07-18-1989
Well Constructor (Business Name): QUINNELLS SEPTIC AND WELL SER INC	Lic. #: 97
Address: RT 2 FRIENDSHIP WI 53934	
Hicap Permanent Well #	Common Well #
Facility ID # (Public Wells)	Well Plan Approval #
Approval Date (mm-dd-yyyy)	Specific Capacity

1. Well Location
Town of PRESTON
Fire # (if avail.)
Street Address or Road Name and Number
Subdivision Name: FPREST DALE SUB. CSM 968 — Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code
NE SE or Govt Lot # — Section: 18 — Township: 18 N — Range: 6 E

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Jetted

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	5
2	5	55

Upper Enlarged Drillhole — Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	16
C	CLAY	16	26
S	SAND	26	38
C	CLAY	38	44
S	SAND	44	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	CYCLOPS CORP. ASTM-A-589 IPS .154 WALL 3.75 3/FTT@C	Surface	52
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.25	3' CLAYTON MARK 60 GAUZE	52	55

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 10 GP for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DQ		07-18-1989
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JF		07-18-1989

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		76	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 11-28-1989 Updated On: 11-28-1989 Review Status: