

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CL961		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BILL GROSS						Phone # (414)468-4340		1. Well Location				Fire # (if avail.)					
Mailing Address 2887 MAYFLOWER RD						Town of WAUSAUKEE						Street Address or Road Name and Number NEJEDLO RD					
City GREEN BAY				State WI		Zip Code 54311											
County Marinette		Co. Permit #		Notification #		Completed 12-06-1990		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) JOHNSON MAURICE				Lic. # 664		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)			Method Code						
Address RT 1 BOX 2A PEMBINE WI 54156				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W		Range 20 E					
								SW		Section 3				Township 33 N			
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type New Well									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		of previous unique well # _____ constructed in _____											
						Reason for replaced or reconstructed well ?											
4. Potential Contamination Sources - ON REVERSE SIDE						Construction Type Drilled											
						5. Drillhole Dimensions and Construction Method						8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		60		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		C S		SANDY CLAY		Surface		60			
6		60		360						Q		GRANITE ROCK		60		360	
6. Casing, Liner, Screen						9. Static Water Level						11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		30 ft. below ground surface							
6		VALLEY STEEL .280 W A53 TESTED 1780				Surface		60		10. Pump Test							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 250 ft. below surface							
										Pumping at 2 GP for 8 Hrs.							
										Pumping Method ?							
7. Grout or Other Sealing Material						12 in. above grade						Developed ? Yes Disinfected ? Yes Capped ? Yes					
Method						12. Notified Owner of need to fill & seal ?											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?									
DRILLING MUD		Surface		60				13. Constructor / Supervisory Driller									
								Lic #		Date Signed		12-18-1990					
								MJ									
								Drill Rig Operator		Lic or Reg #						Date Signed	
												12-18-1990					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		40

Comment:

Created On: 03-27-1991

Updated On: 03-27-1991

Review Status: