Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CL962

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DONALD SCHOWER	Phone #
Mailing Address: N 18925 N MIL ST	
City: PEMBINE	State: WI — Zip Code: 54156
County: Marinette	Co. Permit #	Notification #	Completed: 11-09-1990
Well Constructor (Business Name): JOHNSON MAURICE	Lic. #: 664	Facility ID # (Public Wells)
Address: RT 1 BOX 2A PEMBINE WI 54156	Well Plan Approval #
	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.8

1. Well Location

Town of PEMBINE

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SE NW or Govt Lot #	Section	Township	Range
	26	37 N	20 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	53
6	53	61

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	C	SAND AND CLAY	Surface	53
		G		GRAVEL	53	61

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	VALLEY STEEL 280 WALL TESTED 1780 ASTM A53WELDED JOINTS	Surface	53
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	SS NO 15	53	61

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	53	

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 8 GP for 8 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		12-04-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DJ		12-04-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75
Building Drain - Sanitary		55

Type	Qualifier	Distance
Building Overhang		25
Sewer - Building Sanitary		55
Septic or Holding, or POWTS Tank		65

Comment:

Created On: 03-27-1991 Updated On: 03-27-1991 Review Status: