Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CM375

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LESTER @ ANN OLSON			Phone #
Mailing Address: 1729 LA CRESCENT ST			
City: LA CROSSE	State: WI	Zip Code: 54603	
County: La Crosse	Co. Permit #: W03729	Notification #	Completed: 09-13-1990

Well Constructor (Business Name): AQUA INDUSTRIES INC	Lic. #: 4755	Facility ID # (Public Wells)	
Address: N5262 HWY 53 ONALASKA WI 54650-9250		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of ONALASKA

Fire # (if avail.): N5611

Street Address or Road Name and Number: MOHICAN TRAIL

Subdivision Name	Lot #	Block #
THUNDERBIRD	00007	2

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.9244 °N	-91.2337 °W			GCD013
NE NE or Govt Lot #	Section: 29	Township: 17 N	Range: 7 W	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	88
6	88	137

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Air & Foam .....
Rotary - Mud Circulation .....
Rotary - Air .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	80
G		C		GREY CLAY	80	85
		N		SAND STONE	85	137

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL .280X18.97 A-53 IMPORT WELD	Surface	88
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	88	10

9. Static Water Level
80 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 20 GP for 4 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MS		09-15-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RS		09-14-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 02-12-1992 Updated On: 04-30-2020 Review Status: