Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CM382

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ARTSCHWAGLER, ERIC			Phone #
Mailing Address: RT 1			
City: STODDARD	State: WI	Zip Code: 54650	
County: Vernon	Co. Permit #	Notification #	Completed: 10-31-1990

Well Constructor (Business Name): AQUA INDUSTRIES INC	Lic. # 4755	Facility ID # (Public Wells)	
Address: N5262 HWY 53 ONALASKA WI 54650-9250		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of BERGEN

Fire # (if avail.)

Street Address or Road Name and Number: SUNSHINE DR

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code
SW NW or Govt Lot #	Section: 1	Township: 14 N	Range: 7 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	125
6	125	145

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	10
		H	M	SHALE @ STANDSTONE	10	120
	H	N		HARD SANDSTONE	120	145

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL 2807 18 97 A 53 SAWHILL WELD	Surface	126
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TRIMMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	126	15 S

9. Static Water Level
100 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 20 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RS		10-15-1990
Drill Rig Operator	Lic or Reg #	Date Signed
		10-15-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		108
Building Drain - Sanitary		40
Building Overhang		8
Sewer - Building Sanitary		50
Septic or Holding, or POWTS Tank		56

Comment:

Created On: 11-13-1995 Updated On: 11-13-1995 Review Status: