

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CM382		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																					
Property Owner ARTSCHWAGLER, ERIC					Phone #			1. Well Location				Fire # (if avail.)																			
Mailing Address RT 1					Town of BERGEN							Street Address or Road Name and Number SUNSHINE DR																			
City STODDARD			State WI		Zip Code 54650																										
County Vernon		Co. Permit #		Notification #			Completed 10-31-1990		Subdivision Name			Lot #		Block #																	
Well Constructor (Business Name) AQUA INDUSTRIES INC				Lic. # 4755		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code																			
Address N5262 HWY 53 ONALASKA WI 54650-9250				Well Plan Approval #			SW NW Section Township Range or Govt Lot # 1 14 N 7 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled																						
				Approval Date (mm-dd-yyyy)																											
Hicap Permanent Well #			Common Well #		Specific Capacity 1			3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes																							
Hicap Well ? No Hicap Property ? No Hicap Potable ?																															
4. Potential Contamination Sources - ON REVERSE SIDE																															
5. Drillhole Dimensions and Construction Method												8. Geology																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)													
8		Surface		125		Rotary - Mud Circulation Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)			<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 10%;"> </td> <td style="width: 10%;">C</td> <td style="width: 10%;"> </td> <td style="width: 10%;">CLAY</td> <td style="width: 10%;">Surface</td> <td style="width: 10%;">10</td> </tr> <tr> <td> </td> <td>H</td> <td>M</td> <td>SHALE @ STANDSTONE</td> <td>10</td> <td>120</td> </tr> <tr> <td>H</td> <td>N</td> <td> </td> <td>HARD SANDSTONE</td> <td>120</td> <td>145</td> </tr> </table>				C		CLAY	Surface	10		H	M	SHALE @ STANDSTONE	10	120	H	N		HARD SANDSTONE	120	145	Surface 10 10 120 120 145	
	C		CLAY	Surface	10																										
	H	M	SHALE @ STANDSTONE	10	120																										
H	N		HARD SANDSTONE	120	145																										
6		125		145																											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		100 ft. below ground surface				20 in. above grade																	
6		BLACK STEEL 2807 18 97 A 53 SAWHILL WELD				Surface		126		10. Pump Test Pumping level 120 ft. below surface Pumping at 20 GP M for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes																	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)																							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes																			
Method TRIMMIE																															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement																									
NEAT CEMENT		Surface		126		15 S				13. Constructor / Supervisory Driller				Lic #		Date Signed															
RS		Drill Rig Operator		Lic or Reg #		Date Signed																									
10-15-1990		10-15-1990		10-15-1990																											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		108	Building Overhang		8
Building Drain - Sanitary		40	Sewer - Building Sanitary		50
			Septic or Holding, or POWTS Tank		56

Comment:

Created On: 11-13-1995

Updated On: 11-13-1995

Review Status: