Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CM441

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LARRY PARSON	Phone #: (612)770-6099
Mailing Address: 8234 39TH ST	
City: LAKE ALMO	State: MN Zip Code: 55042
County: Rusk	Co. Permit #:	Notification #:	Completed: 04-14-1992
Well Constructor (Business Name): WILLMARTH, LARRY L	Lic. #: 241
Address: RT 3 BOX 132 HOLCOMBE WI 54745-9739	
Facility ID # (Public Wells):	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.2

1. Well Location

Fire # (if avail.):

Town of WILLARD

Street Address or Road Name and Number: ST HWY 194

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SE NW or Govt Lot #	Section	Township	Range
	34	33 N	6 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: TO GET WATER FOR TRAILER

Construction Type: Drilled

3. Well serves 1 # of TRAILER HOUSE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	53

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		SAND/CAVING/BROWN/SOFT	Surface	41
	V	P		HARD PAN/NONCAVING/BROWN/HARD	41	52
K		Q		GRANITE/NONCAVING/BLACK	52	53

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	O.D.X.280 WX 18.97#/FT ASTMA53 88A GRD B P.E. BEV	Surface	52
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

16 ft. below ground surface

10. Pump Test

Pumping level 39 ft. below surface

Pumping at 4 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LW		04-14-1992
Drill Rig Operator	Lic or Reg #	Date Signed
LW		04-14-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50
Building Overhang		30
Landfill		1400
Sewer - Building Sanitary		60
Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 05-21-1992 Updated On: 05-21-1992 Review Status: