

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CM455		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																			
Property Owner RICHARD TANGNEY						Phone #																							
Mailing Address RT 2 18TH AVE						Town of QUINCY						Fire # (if avail.) 2400																	
City FRIENDSHIP						State WI		Zip Code 53934				Street Address or Road Name and Number 18TH AVE																	
County Adams		Co. Permit #		Notification #		Completed 09-25-1990		Subdivision Name PINEORAMA				Lot # 00B25		Block #															
Well Constructor (Business Name) BAUMEL SEPTIC AND WELL SERVICE				Lic. # 4682		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code															
Address 1335 DUCK CREEK CT ADAMS WI 53910				Well Plan Approval #				SW SW Section Township Range or Govt Lot # 33 17 N 5 E		Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #				Common Well #		Specific Capacity				Reason for replaced or reconstructed well ?																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?						Construction Type Jetted																	
4. Potential Contamination Sources - ON REVERSE SIDE																													
5. Drillhole Dimensions and Construction Method																													
<table style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 40%; border: 1px solid black; padding: 5px;"> Upper Enlarged Drillhole Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia </td> <td style="width: 60%; border: 1px solid black; padding: 5px;"> Lower Open Bedrock </td> </tr> </table>														Upper Enlarged Drillhole Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia	Lower Open Bedrock														
Upper Enlarged Drillhole Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia	Lower Open Bedrock																												
8. Geology																													
<table style="width:100%; border-collapse: collapse;"> <tr> <th style="width: 10%;">Geology Codes</th> <th style="width: 50%;">Type, Caving/Noncaving, Color, Hardness, etc...</th> <th style="width: 15%;">From (ft.)</th> <th style="width: 15%;">To (ft.)</th> </tr> <tr> <td style="text-align: center;">S</td> <td>SAND</td> <td style="text-align: center;">Surface</td> <td style="text-align: center;">28</td> </tr> <tr> <td style="text-align: center;">C</td> <td>CLAY</td> <td style="text-align: center;">28</td> <td style="text-align: center;">32</td> </tr> <tr> <td style="text-align: center;">S G</td> <td>SAND @ GRAVEL</td> <td style="text-align: center;">32</td> <td style="text-align: center;">66</td> </tr> </table>														Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)	S	SAND	Surface	28	C	CLAY	28	32	S G	SAND @ GRAVEL	32	66
Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)																										
S	SAND	Surface	28																										
C	CLAY	28	32																										
S G	SAND @ GRAVEL	32	66																										
6. Casing, Liner, Screen																													
Removed? ___ depth ft. (If NO explain on back side)																													
<table style="width:100%; border-collapse: collapse;"> <tr> <th style="width: 10%;">Dia. (in.)</th> <th style="width: 40%;">Material, Weight, Specification Manufacturer & Method of Assembly</th> <th style="width: 15%;">From (ft.)</th> <th style="width: 15%;">To (ft.)</th> </tr> <tr> <td style="text-align: center;">2</td> <td>STEEL</td> <td style="text-align: center;">Surface</td> <td style="text-align: center;">63</td> </tr> <tr> <th style="width: 10%;">Dia. (in.)</th> <th style="width: 40%;">Screen type, material & slot size</th> <th style="width: 15%;">From (ft.)</th> <th style="width: 15%;">To (ft.)</th> </tr> <tr> <td style="text-align: center;">1.25</td> <td>JOHNSON PT</td> <td style="text-align: center;">63</td> <td style="text-align: center;">66</td> </tr> </table>														Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)	2	STEEL	Surface	63	Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)	1.25	JOHNSON PT	63	66
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)																										
2	STEEL	Surface	63																										
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)																										
1.25	JOHNSON PT	63	66																										
7. Grout or Other Sealing Material Method																													
9. Static Water Level 18 ft. below ground surface																													
10. Pump Test Pumping level ___ ft. below surface Pumping at ___ GP for ___ Hrs. Pumping Method ?																													
11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes																													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes																													
13. Constructor / Supervisory Driller																													
DJ										Lic #		Date Signed 09-25-1990																	
Drill Rig Operator										Lic or Reg #		Date Signed 09-25-1990																	
MB																													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Septic or Holding, or POWTS Tank	>	25

Comment:

Created On: 07-16-1991

Updated On: 07-16-1991

Review Status: