Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CM796

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TOM WALTON		Phone #: (608)776-2295
Mailing Address: 13820 WILLOW SPGS LN		
City: DARLINGTON	State: WI	Zip Code: 53530

County	Co. Permit #	Notification #	Completed
Lafayette			11-13-1990

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
WEBBER JR WILLIAM G	442	

Address: 21781 HWY 11 WEST
SHULLSBURG WI 53586

Hicap Permanent Well #	Common Well #	Specific Capacity

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of DARLINGTON

Fire # (if avail.): 13820

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
42.6944 °N	-90.1144 °W			GCD013

NW or Govt Lot #	NW	Section	Township	Range
		34	3 N	3 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NO WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	43
6	43	120

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 10in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		SOIL	Surface	10
		G		BOULDERS	10	15
G		L		GREY LIMESTONE	15	73
		N		ST PETER SANDSTONE	73	120

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ST P/E 18.97 CAC 6.625 .280 WT 398 LBS 5LX12/5LL A53 BE 21	Surface	43
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	43	30

9. Static Water Level
70 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 15 GP for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RLW		11-13-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RLW		11-13-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		40
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-28-1991 Updated On: 09-04-2019 Review Status: