

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CM797		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner WILLIS DISCH						Phone # (608)527-2325		1. Well Location				Fire # (if avail.)							
Mailing Address PO BOX 478						Town of NEW GLARUS						Street Address or Road Name and Number							
City NEW GLARUS				State WI		Zip Code 53574													
County Green		Co. Permit #		Notification #		Completed 11-15-1990		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) WEBBER JR WILLIAM G				Lic. # 442		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 21781 HWY 11 WEST SHULLSBURG WI 53586				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 15 4 N 7 E		2. Well Type New Well				of previous unique well # constructed in							
Hicap Permanent Well #		Common Well #		Specific Capacity 6		Reason for replaced or reconstructed well ? NON-CONFORMING WELL													
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No				Construction Type Drilled									
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		42		Rotary - Mud Circulation						C G		CLAY @ BOULDERS		Surface		14	
6		42		100		Rotary - Air						L		MAGNESIUM LIMESTONE		14		100	
						Rotary - Air & Foam													
						Drill-Through Casing Hammer													
						Reverse Rotary													
						Cable-tool Bit 10in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		65 ft. below ground surface				12 in. above grade					
6		NEW BLK. ST. PE 18.97 CAC 6 5/8 OD .280 WT 398 LBS 5LX 12/5LL A53 B E21				Surface		42		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 70 ft. below surface				Disinfected ? Yes					
										Pumping at 30 GP for 4 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method TREMMIE PIPE												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
NEAT CEMENT				Surface		42		30		WGWJ						11-15-1990			
										Drill Rig Operator				Lic or Reg #		Date Signed			
										WGWJ									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Downspout/Yard Hydrant		25
Building Overhang		10	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-28-1991

Updated On: 03-28-1991

Review Status: