Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CM799

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BERT BERGLUND			Phone #: (708)428-2464
Mailing Address: 17 N080 SLEEPY HLW			
City: DUNDEE	State: IL	Zip Code: 60118	
County: Green	Co. Permit #:	Notification #:	Completed: 12-01-1990

Well Constructor (Business Name): WEBBER JR WILLIAM G	Lic. #: 442	Facility ID # (Public Wells):	
Address: 21781 HWY 11 WEST SHULLSBURG WI 53586		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of MONROE

Fire # (if avail.):

Street Address or Road Name and Number: BUEHLER RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

SE	NE	Section	Township	Range
or Govt Lot #		3	2 N	7 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD WELL PUMPED DRY

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	84
6	84	185

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	CLAY AND BOULDERS	Surface	7
	S	L		LOOSE BRN LIMESTONE	7	20
T		L		BROWN DOLOMITE	20	60
G		L		GREY DOLOMITE	60	75
U		L		BLUE DOLOMITE	75	80
T		L		BROWN DOLOMITE	80	90
		L		TRENTON LIMESTONE	90	161
		N		ST PETER SANDSTONE	161	185

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ST PE 18.97 CAC 6.625 OD .280 WT 398 LBS5LX12/5LL A53 BE21	Surface	84
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	84	40

9. Static Water Level
80 ft. below ground surface

10. Pump Test
Pumping level 95 ft. below surface
Pumping at 15 GP for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
WGJ		12-07-1990
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
WGJ		12-07-1990

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		25	Barn Gutter		100
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 03-28-1991 Updated On: 03-28-1991 Review Status: