Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CN298

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: CHARLES VOGL	Phone #: (414)764-1842
Mailing Address: 1402 MANISTIQUE	
City: S MILWAUKEE	State: WI — Zip Code: 53172
County: Ashland	Co. Permit #: — Notification #: — Completed: 03-03-1992
Well Constructor (Business Name): BUTTERFIELD, THOMAS G	Lic. #: 555 — Facility ID # (Public Wells):
Address: RT 1 BOX 1086 HAYWARD WI 54843-9790	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0

1. Well Location
Town of MORSE
Fire # (if avail.):
Street Address or Road Name and Number:
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

SW	SW	Section	Township	Range
or Govt Lot #		14	44 N	2 W

2. Well Type New Well
of previous unique well #: constructed in:
Reason for replaced or reconstructed well ?
NEW MOBILE HOME
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	144

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	C	M	CAVING BEDDED REDDISH BRN CLAY SILTY SAN	Surface	115.5
R		S	G	CLEANER SILTY RED SAND W/TRAP ROCK CHUNC	115.5	116.2
	F	B		TRAP ROCK W/UPPER PART VERTICAL CRACKS.	116.2	144

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW P@E BLACK WELDED 18:97LB PER FT. ASTM-A53B	Surface	116
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
9 ft. below ground surface

10. Pump Test
Pumping level 110 ft. below surface
Pumping at 5 GP for 2 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NEW MOBILE HOME

13. Constructor / Supervisory Driller	Lic #	Date Signed
TB		03-12-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TB		03-12-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		83	Shoreline/Pool		105
			Septic or Holding, or POWTS Tank		62

Comment:

Created On: 04-23-1992 Updated On: 10-15-2026 Review Status: