Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CN299

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: KEVIN WOHLFORD	Phone #: (715)635-3419
Mailing Address: RT 2	
City: SPOONER	State: WI — Zip Code: 54801
County: Washburn	Co. Permit #: — Notification #: — Completed: 03-05-1992
Well Constructor (Business Name): BUTTERFIELD, THOMAS G	Lic. #: 555 — Facility ID # (Public Wells):
Address: RT 1 BOX 1086 HAYWARD WI 54843-9790	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2

1. Well Location

Town of CRYSTAL				Fire # (if avail.):
Street Address or Road Name and Number: HWY 70				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code:
SE SW or Govt Lot #:	Section: 36	Township: 39 N	Range: 11 W	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?: NEW HOUSE
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	37

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	I	G		TIGHT ROCKY SOIL	Surface	6
W	S	U		FINE T MED SAND DIRTY (W.)	6	29
	C	G		CLAY W/SOME GRAVELS	29	33
M	S			MED SAND CLEAN (W.)	33	37

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW P@E BLACK WELDED 10:79LB PER FT ASTMA53B	Surface	34
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	STAINLESS STEEL SCREEN 18 SLOT	34	37

9. Static Water Level
7 ft. below ground surface

10. Pump Test
Pumping level 12 ft. below surface
Pumping at 10 GP for 2 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NEW HOUSE

13. Constructor / Supervisory Driller	Lic #	Date Signed
TB		03-05-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TB		03-05-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-23-1992 Updated On: 04-23-1992 Review Status: