

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CN300		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner KEITH MILES						Phone # (715)634-4580		1. Well Location				Fire # (if avail.)				
Mailing Address RT 3						Town of LENROOT						Street Address or Road Name and Number				
City HAYWARD				State WI		Zip Code 54843										
County Sawyer		Co. Permit #		Notification #		Completed 11-06-1991		Subdivision Name			Lot #		Block #			
Well Constructor (Business Name) BUTTERFIELD, THOMAS G				Lic. # 555		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code					
Address RT 1 BOX 1086 HAYWARD WI 54843-9790				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW SW Section Township Range or Govt Lot # 35 42 N 9 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? CABIN						
Hicap Permanent Well #		Common Well #		Specific Capacity 2.9												
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled										
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method												8. Geology				
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
4 Surface 100.58			Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				T N S		A G S A S S G C N S X G A S C A S C Y C C S A G		SMALL GRAVEL W/COARSE SAND COARSE SAND SAND W/ANGULAR GRAVEL CLAY LIGHT BROWN FINE SAND CLAY/SAND SMALL ANGULAR GRAVEL COARSE SAND CLAY GRAVEL COARSE SAND (W) FE DARK CLAY SAND GRAVEL DARK CLAY FINE SAND CLAY FINE SAND SMALL ROCK COARSE GRAVEL (W)		Surface 16 21 31 35 41 43 46 61 90 95 95		15 20 30 34 40 42 45 60 90 95 100.58	
6. Casing, Liner, Screen																
Dia. (in.) Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.) To (ft.)													
4 NEW P@E BLACK WELDED ASTM A-53BB 10:79 LB SOFTSAWHILL PIPE			Surface 100.58													
Dia. (in.) Screen type, material & slot size			From (ft.) To (ft.)													
7. Grout or Other Sealing Material Method																

9. Static Water Level

38 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 20 GP for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

No

CABIN

13. Constructor / Supervisory Driller

Lic #

Date Signed

TB

11-06-1991

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 06-29-1992

Updated On: 06-29-1992

Review Status: