Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CN300

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KEITH MILES	Phone #: (715)634-4580
Mailing Address: RT 3	
City: HAYWARD	State: WI — Zip Code: 54843
County: Sawyer	Co. Permit #: — Notification #: — Completed: 11-06-1991
Well Constructor (Business Name): BUTTERFIELD, THOMAS G	Lic. #: 555 — Facility ID # (Public Wells):
Address: RT 1 BOX 1086 HAYWARD WI 54843-9790	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2.9

1. Well Location

Town of LENROOT

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SW SW or Govt Lot # — Section: 35 — Township: 42 N — Range: 9 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

CABIN

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	100.58

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

	Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	A	G	S	SMALL GRAVEL W/COARSE SAND	Surface	15
	A	S		COARSE SAND	16	20
		S	G	SAND W/ANGULAR GRAVEL	21	30
T		C		CLAY LIGHT BROWN	31	34
	N	S		FINE SAND	35	40
		X	G	CLAY/SAND SMALL ANGULAR GRAVEL	41	42
	A	S	C	COARSE SAND CLAY GRAVEL	43	45
	A	S	C	COARSE SAND (W) FE DARK CLAY	46	60
		Y	C	SAND GRAVEL DARK CLAY FINE SAND	61	90
		C	S	CLAY FINE SAND SMALLROCK	90	95
	A	G		COARSE GRAVEL (W)	95	100.58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW P@E BLACK WELDED ASTM A-53BB 10:79 LB SOFTSAWHILL PIPE	Surface	100.58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

9. Static Water Level

38 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 20 GP for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

CABIN

13. Constructor / Supervisory Driller	Lic #	Date Signed
TB		11-06-1991
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Septic or Holding, or POWTS Tank		65

Comment:

Created On: 06-29-1992 Updated On: 06-29-1992 Review Status: