

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CN345		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner DONALD BRIETZMAN						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address RT 1						Town of WINTER						Street Address or Road Name and Number					
City WINTER				State WI		Zip Code 54896											
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #			
Sawyer		11-15-1990		Well Constructor (Business Name) DAVIS DAVID		Lic. # 642		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code	
Address HCR3 BOX 42 PHILLIPS WI 54555						Well Plan Approval #		°N		°W		NW NE Section Township Range or Govt Lot # 33 39 N 5 W					
		Approval Date (mm-dd-yyyy)		2. Well Type New Well of previous unique well # constructed in													
Hicap Permanent Well #		Common Well #				Specific Capacity 0.8		Reason for replaced or reconstructed well ?									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		60		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		S G SAND AND FINE GRAVEL C G CLAY AND ROCKS Y U MUDDY SAND AND GRAVEL W S G WATER BEARING SAND AND GRAVEL		Surface		22					
6 BLK STEEL 18.97 P/E A53 SUMITOMO		Surface		60						22		50					
		Screen type, material & slot size		From (ft.)						To (ft.)		50		58			
6 BLK STEEL 18.97 P/E A53 SUMITOMO		Surface		60		58		60									
6. Casing, Liner, Screen						9. Static Water Level						11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		21 ft. below ground surface				12 in. above grade			
6		BLK STEEL 18.97 P/E A53 SUMITOMO				Surface		60		Pumping level 33 ft. below surface				Developed ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 10 GP for 2 Hrs.				Disinfected ? Yes			
7. Grout or Other Sealing Material Method		Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?				Capped ? Yes							
7. Grout or Other Sealing Material Method						13. Constructor / Supervisory Driller				Lic #		Date Signed					
						DD				11-15-1990							
						Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85	Shoreline/Pool		160
Building Overhang		19	Sewer - Building Sanitary		65
			Septic or Holding, or POWTS Tank		75

Comment: WELL NOT ON HIGHEST POINT OF PROPERTY AS ONLY LOCATION FOR WELL WAS IN FRONT OF HOUSE, DOWNHILL SIDE

Created On: 03-21-1991**Updated On:** 03-21-1991**Review Status:**