

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CN444		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner ARNOLD @ GEORGA PETERSEN						Phone # (608)584-5532		1. Well Location				Fire # (if avail.)			
Mailing Address 2760 8TH CT						Town of EASTON						2760			
City ADAMS						State WI		Zip Code 53910				Street Address or Road Name and Number 8TH COURT			
County Adams		Co. Permit #		Notification #		Completed 02-26-1991		Subdivision Name DEER LOOKOUT				Lot # 00008		Block #	
Well Constructor (Business Name) QUINNELLS SEPTIC AND WELL SER IN				Lic. # 97		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code	
Address RT 2 FRIENDSHIP WI 53934				Well Plan Approval #		°N °W				Township				Range	
						NW SE Section Township Range or Govt Lot # 23 16 N 6 E									
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type Replacement					
Reason for replaced or reconstructed well ? OLD WELL SLOW															
3. Well serves 1 # of				Hicap Well ? No		Construction Type Jetted									
Private, potable				Hicap Property ? No											
Heat Exchange ____ # of drillholes				Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
6 Surface 5			Rotary - Mud Circulation												
2 5 55			Rotary - Air												
			Rotary - Air & Foam												
			Drill-Through Casing Hammer												
			Reverse Rotary												
			Cable-tool Bit ____ in. dia...												
			Dual Rotary												
			Temp. Outer Casing ____ in. dia												
			Removed? ____ depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)						
S			SAND						Surface 14						
C			CLAY						14 30						
S			SAND						30 45						
A S			COARSE SAND						45 55						
6. Casing, Liner, Screen															
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)								
2			CYCLOPS CORP. ASTM-A-589 IPS .154 WALL 3.75#FTTHREADED COUPLINGS				Surface 52								
Dia. (in.)			Screen type, material & slot size				From (ft.) To (ft.)								
1.25			3' CLAYTON MARK 60 GAUZE				52 55								
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material			From (ft.) To (ft.)		# Sacks Cement										
SAND			Surface 0												
9. Static Water Level															
30 ft. below ground surface															
10. Pump Test															
Pumping level 30 ft. below surface															
Pumping at 10 GP for 1 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #			Date Signed												
DDQ			02-26-1991												
Drill Rig Operator			Lic or Reg #			Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		5
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 07-12-1991

Updated On: 07-12-1991

Review Status: