Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CN444

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ARNOLD @ GEORGA PETERSEN		Phone #: (608)584-5532
Mailing Address: 2760 8TH CT		
City: ADAMS	State: WI	Zip Code: 53910

County	Co. Permit #	Notification #	Completed
Adams			02-26-1991

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
QUINNELLS SEPTIC AND WELL SER IN	97	

Address: RT 2
FRIENDSHIP WI 53934

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.): 2760

Town of EASTON

Street Address or Road Name and Number: 8TH COURT

Subdivision Name	Lot #	Block #
DEER LOOKOUT	00008	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NW SE or Govt Lot #	Section	Township	Range
	23	16 N	6 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD WELL SLOW

Construction Type: Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	5
2	5	55

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	14
		C		CLAY	14	30
		S		SAND	30	45
	A	S		COARSE SAND	45	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	CYCLOPS CORP. ASTM-A-589 IPS .154 WALL 3.75#/FTTHREADED COUPLINGS	Surface	52
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	3' CLAYTON MARK 60 GAUZE	52	55

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
SAND	Surface	0	

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 10 GP for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DDQ		02-26-1991
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		5
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 07-12-1991 Updated On: 07-12-1991 Review Status: