Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CN446

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GERTRUDE DRIKWINE			Phone #: (608)339-6376
Mailing Address: 2148 MARKET ST			
City: FRIENDSHIP	State: WI	Zip Code: 53934	
County: Adams	Co. Permit #:	Notification #:	Completed: 03-18-1991

Well Constructor (Business Name): QUINNELLS SEPTIC AND WELL SER IN	Lic. #: 97	Facility ID # (Public Wells):
Address: RT 2 FRIENDSHIP WI 53934		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity:

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of QUINCY

Fire # (if avail.): 2148

Street Address or Road Name and Number: MARKET STREET

Subdivision Name: DELLWOOD	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 43.9448 °N -89.9495 °W
Method Code: GCD013

SE NW or Govt Lot #	Section: 18	Township: 17 N	Range: 5 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD WELL SLOW

Construction Type: Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	5
2	5	45

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	27
C	CLAY	27	34
S	SAND	34	38
A S	COARSE SAND	38	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	CYCLOPS CORP. ASTM-A-589 IPS .154 WALL 3.75#/FT 2THREADED COUPLING	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	3' CLAYTON MARK 60 GAUZE	42	45

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
SAND	Surface	0	

9. Static Water Level
16 ft. below ground surface

10. Pump Test
Pumping level 16 ft. below surface
Pumping at 10 GP for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DDQ		03-18-1991
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		53	Building Overhang		4
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 07-12-1991 Updated On: 05-04-2020 Review Status: