Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CN596

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MILLS FLEET FARM		Phone #	
Mailing Address: HWY 45 S			
City: CLINTONVILLE	State: WI	Zip Code: 54929	
County: Waupaca	Co. Permit #	Notification #	Completed: 12-15-1990

Well Constructor (Business Name): DILLENBURG DANIEL	Lic #: 196	Facility ID # (Public Wells)
Address: RT 3 BOX 247 SHAWANO WI 54166		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.5

1. Well Location

Town of LARRABEE

Fire # (if avail.)

Street Address or Road Name and Number: HWY 45

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NE NW or Govt Lot #:	Section: 35	Township: 25 N	Range: 14 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: 2# WELL

Construction Type: Drilled

3. Well serves 1 # of STORE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	175

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Yes Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	S	SANDY CLAY	Surface	14
		S		SAND	14	22
	N	S		FINE FINE SAND	22	58
		M		SILT	58	120
		C	M	SILTY CLAY	120	155
		C	G	CLAY AND STONE	155	172
		G	U	MUDDY GRAVEL	172	175

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53 18.97 SAWHILL WELDED	Surface	175
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

41 ft. below ground surface

10. Pump Test

Pumping level 82 ft. below surface

Pumping at 20 GP for 10 Hrs.

Pumping Method ?

11. Well Is

22 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method CIRCULATION

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	175	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DD		01-09-1991
Drill Rig Operator	Lic or Reg #	Date Signed
		01-09-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		140	Septic or Holding, or POWTS Tank		140

Comment:

Created On: 04-04-1991 Updated On: 04-08-2003 Review Status: