

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CN596		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner MILLS FLEET FARM						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address HWY 45 S						Town of LARRABEE															
City CLINTONVILLE						State WI		Zip Code 54929													
County Waupaca		Co. Permit #		Notification #		Completed 12-15-1990		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) DILLENBURG DANIEL				Lic. # 196		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address RT 3 BOX 247 SHAWANO WI 54166				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 35 25 N 14 E		2. Well Type Replacement				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		Reason for replaced or reconstructed well ? 2# WELL															
3. Well serves 1 # of STORE				Hicap Well ? No		Construction Type Drilled															
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method												8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
8		Surface		175		Yes Rotary - Mud Circulation Yes Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				C S SANDY CLAY S SAND N S FINE FINE SAND M SILT C M SILTY CLAY C G CLAY AND STONE G U MUDDY GRAVEL		Surface 14 22 22 58 58 120 120 155 155 172 172 175		14 22 58 120 155 172 175							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		41 ft. below ground surface				22 in. above grade							
6		ASTM A53 18.97 SAWHILL WELDED				Surface		175		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 82 ft. below surface Pumping at 20 GP for 10 Hrs. Pumping Method ?											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?									
Method CIRCULATION												Filled & Sealed Well(s) as needed? No									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
DRILLING MUD				Surface		175															
												13. Constructor / Supervisory Driller				Lic #		Date Signed			
												DD						01-09-1991			
												Drill Rig Operator				Lic or Reg #		Date Signed			
																		01-09-1991			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		140	Septic or Holding, or POWTS Tank		140

Comment:

Created On: 04-04-1991

Updated On: 04-08-2003

Review Status: