

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CN599		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707 Form 3300-077A			
Property Owner STEVE PINGEL					Phone #		1. Well Location Fire # (if avail.) Town of RICHMOND Street Address or Road Name and Number CT A		
Mailing Address RT 2 BOX 100									
City SHAWANO			State WI	Zip Code 54166					
County Shawano	Co. Permit #	Notification #		Completed 12-12-1990		Subdivision Name		Lot #	Block #
Well Constructor (Business Name)		Lic. #	Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD)		Method Code	
DILLENBURG DANIEL		196				°N °W			
Address RT 3 BOX 247 SHAWANO WI 54166		Well Plan Approval #			SW	SW	Section	Township	Range
		Approval Date (mm-dd-yyyy)			or Govt Lot #	8	27	N	15 E
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type Replacement of previous unique well # constructed in 90 Reason for replaced or reconstructed well ? SLOW IN PIT Construction Type Drilled			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?					
4. Potential Contamination Sources - ON REVERSE SIDE									
5. Drillhole Dimensions and Construction Method									
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole Lower Open Bedrock						
8	Surface	59	Yes Rotary - Mud Circulation Yes Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						
6	59	345							
8. Geology									
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)	
	C	S	SANDY CLAY				Surface		30
	S	G	SAND @ GRAVEL				30		34
	C		CLAY				34		59
	Q		GRANITE				59		345
6. Casing, Liner, Screen									
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)				
6	ASTMA53 18.97 SAWHILL WELDED			Surface	59				
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)				
7. Grout or Other Sealing Material									
Method CIRCULATION									
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement					
DRILLING MUD		Surface	59						
9. Static Water Level 36 ft. below ground surface									
10. Pump Test Pumping level 200 ft. below surface Pumping at 2 GP for 10 Hrs. Pumping Method ?									
11. Well Is 22 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes									
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No									
13. Constructor / Supervisory Driller				Lic #		Date Signed			
DD						02-18-1991			
Drill Rig Operator				Lic or Reg #		Date Signed			
						02-18-1991			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		89	Silo/Storage Tube		129
Building Overhang		12	Animal Yard - Include Hutches		70
			Septic or Holding, or POWTS Tank		63

Comment:

Created On: 07-15-1991

Updated On: 07-15-1991

Review Status: