

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CN933		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner RON EMMERICH					Phone # (715)588-9145		1. Well Location				Fire # (if avail.)								
Mailing Address PO BOX 663					Town of ARBOR VITAE														
City WOODRUFF					State WI		Zip Code 54568					Street Address or Road Name and Number AV 1815 FAWN CT							
County Vilas		Co. Permit #		Notification #		Completed 05-13-1992		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) BECKLEY, TERRENCE				Lic. # 353		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.93925 °N -89.67584 °W				Method Code GPS008							
Address 3107 HWY 51 TOMAHAWK WI 54487-8838				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 24 40 N 6 E		2. Well Type New Well of previous unique well # constructed in											
				Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ? NEW HOME													
Hicap Permanent Well #		Common Well #		Specific Capacity 1.4		Construction Type Drilled													
3. Well serves 1 # of Private, potable				Hicap Well ? No															
Heat Exchange ____ # of drillholes				Hicap Property ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		79		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)		Y		SAND @ GRAVEL		Surface		79					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		55 ft. below ground surface				12 in. above grade					
6		P.E. 18.97 LBS. PER FOOT ASTM A-53-B VSPCO TESTED1780# PSI				Surface		79		10. Pump Test Pumping level 65 ft. below surface Pumping at 14 GP for 16 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
6		NOM STAINLESS STEEL #10 X 3'				76		79											
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												TB						05-15-1992	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												TB							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		12
Building Drain - Sanitary		40	Sewer - Building Sanitary		40
			Septic or Holding, or POWTS Tank		38

Comment:

Created On: 06-19-1992

Updated On: 08-19-2022

Review Status: