Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CN933

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RON EMMERICH			Phone #: (715)588-9145
Mailing Address: PO BOX 663			
City: WOODRUFF	State: WI	Zip Code: 54568	
County: Vilas	Co. Permit #:	Notification #:	Completed: 05-13-1992

Well Constructor (Business Name): BECKLEY, TERRENCE	Lic. #: 353	Facility ID # (Public Wells):	
Address: 3107 HWY 51 TOMAHAWK WI 54487-8838		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of ARBOR VITAE

Fire # (if avail.):

Street Address or Road Name and Number
AV 1815 FAWN CT

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.93925 °N	-89.67584 °W			GPS008
NE NE or Govt Lot #	Section: 24	Township: 40 N	Range: 6 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	79

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	79

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. 18.97 LBS. PER FOOT ASTM A-53-B VSPCO TESTED1780# PSI	Surface	79
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	NOM STAINLESS STEEL #10 X 3'	76	79

7. Grout or Other Sealing Material
Method

9. Static Water Level
55 ft. below ground surface

10. Pump Test
Pumping level 65 ft. below surface
Pumping at 14 GP for 16 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TB		05-15-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TB		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65
Building Drain - Sanitary		40

Type	Qualifier	Distance
Building Overhang		12
Sewer - Building Sanitary		40
Septic or Holding, or POWTS Tank		38

Comment:

Created On: 06-19-1992 Updated On: 08-19-2022 Review Status: