

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CN934		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner ROBIN RICHARDSON						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 1066 KIEWERT ST						Town of KING						Street Address or Road Name and Number PICKEREL CREEK AVE									
City WATERTOWN				State WI		Zip Code 53094															
County Lincoln		Co. Permit #		Notification #		Completed 05-18-1992		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) BECKLEY, TERRENCE				Lic. # 353		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address 3107 HWY 51 TOMAHAWK WI 54487-8838				Well Plan Approval #				NW SE		Section 13		Township 35 N		Range 7 E							
				Approval Date (mm-dd-yyyy)				or Govt Lot #		2. Well Type New Well		of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4				Construction Type Drilled													
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.) 6		From (ft.) Surface		To (ft.) 66		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
						Rotary - Mud Circulation								S		SAND		Surface		45	
						Rotary - Air								X		SAND @ CLAY		45		62	
						Rotary - Air & Foam								S		SAND		62		66	
						Drill-Through Casing Hammer															
						Reverse Rotary															
						Cable-tool Bit ____ in. dia...															
Dual Rotary																					
Temp. Outer Casing ____ in. dia																					
Removed? ____ depth ft. (If NO explain on back side)																					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) Surface		To (ft.) 63		38 ft. below ground surface				12 in. above grade							
Dia. (in.) 6		P.E. 18.97 LBS. PER FOOT ASTM A-53B VSPCO-TESTED 1780# PSI				Surface		63		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
										Screen type, material & slot size								Pumping level 55 ft. below surface			
6		NOM STAINLESS STEEL #12 X 3'				63		66		Pumping at 6 GP for 24 Hrs.											
										Pumping Method ?											
7. Grout or Other Sealing Material Method														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														TB						05-31-1992	
														Drill Rig Operator				Lic or Reg #		Date Signed	
														TB							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		10

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: