Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CN934

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROBIN RICHARDSON			Phone #
Mailing Address: 1066 KIEWERT ST			
City: WATERTOWN	State: WI	Zip Code: 53094	
County: Lincoln	Co. Permit #	Notification #	Completed: 05-18-1992

Well Constructor (Business Name): BECKLEY, TERRENCE	Lic. #: 353	Facility ID # (Public Wells)	
Address: 3107 HWY 51 TOMAHAWK WI 54487-8838		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of KING

Fire # (if avail.)

Street Address or Road Name and Number
PICKEREL CREEK AVE

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code
NW SE or Govt Lot #	Section: 13	Township: 35 N	Range: 7 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	66

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	45
X	SAND @ CLAY	45	62
S	SAND	62	66

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. 18.97 LBS. PER FOOT ASTM A-53B VSPCO-TESTED1780# PSI	Surface	63
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	NOM STAINLESS STEEL #12 X 3'	63	66

7. Grout or Other Sealing Material
Method

9. Static Water Level
38 ft. below ground surface

10. Pump Test
Pumping level 55 ft. below surface
Pumping at 6 GP for 24 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TB		05-31-1992
Drill Rig Operator	Lic or Reg #	Date Signed
TB		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		10

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: