

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CN936		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner RICHARD TALLMAN Phone # (715)366-4606						1. Well Location				Fire # (if avail.)							
Mailing Address AV 1325 OLD HWY 51 S						Town of ARBOR VITAE				Street Address or Road Name and Number JOHNSON CREEK RD							
City WOODRUFF				State WI		Zip Code 54568											
County Vilas		Co. Permit #		Notification #		Completed 05-29-1992		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) BECKLEY, TERRENCE				Lic. # 353		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address 3107 HWY 51 TOMAHAWK WI 54487-8838				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 33 40 N 6 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME									
Approval Date (mm-dd-yyyy)				Specific Capacity 0.3		Construction Type Drilled											
Hicap Permanent Well #				Common Well #		Hicap Well ? No Hicap Property ? No Hicap Potable ?		Heat Exchange ___ # of drillholes									
3. Well serves 1 # of Private, potable				4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		139		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		S		SAND		Surface		30			
6		P.E. 18.97 LBS. PER FOOT ASTM A-53B VSPCO TESTED 1780# PSI		Surface				136		N S C		FINE SAND W/CLAY		30		43	
										C		CLAY		43		123	
										N S C		FINE SAND W/CLAY		123		133	
										S		SAND		133		139	
										6		NOM STAINLESS STEEL #7 X 3'		136		139	
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface				12 in. above grade			
6		P.E. 18.97 LBS. PER FOOT ASTM A-53B VSPCO TESTED 1780# PSI				Surface		136		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 50 ft. below surface Pumping at 10 GP for 24 Hrs. Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?			
6		NOM STAINLESS STEEL #7 X 3'				136		139									
7. Grout or Other Sealing Material Method						13. Constructor / Supervisory Driller						Lic #		Date Signed			
Method						TB						05-29-1992					
						Drill Rig Operator						Lic or Reg #		Date Signed			
						TB						Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55	Building Overhang		3
Building Drain - Sanitary		30	Sewer - Building Sanitary		30
			Septic or Holding, or POWTS Tank		42

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: