Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CN936

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RICHARD TALLMAN	Phone #: (715)366-4606
Mailing Address: AV 1325 OLD HWY 51 S	
City: WOODRUFF	State: WI — Zip Code: 54568
County: Vilas	Co. Permit #: — Notification #: — Completed: 05-29-1992
Well Constructor (Business Name): BECKLEY, TERRENCE	Lic. #: 353 — Facility ID # (Public Wells):
Address: 3107 HWY 51 TOMAHAWK WI 54487-8838	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.3

1. Well Location

Town of ARBOR VITAE

Fire # (if avail.):

Street Address or Road Name and Number: JOHNSON CREEK RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

or Govt Lot #	Section	Township	Range
SE SE	33	40 N	6 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	139

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	S			SAND	Surface	30
N	S	C		FINE SAND W/CLAY	30	43
	C			CLAY	43	123
N	S	C		FINE SAND W/CLAY	123	133
	S			SAND	133	139

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. 18.97 LBS. PER FOOT ASTM A-53B VSPCO TESTED1780# PSI	Surface	136
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	NOM STAINLESS STEEL #7 X 3'	136	139

7. Grout or Other Sealing Material

Method

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 10 GP for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TB		05-29-1992
Drill Rig Operator	Lic or Reg #	Date Signed
TB		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55
Building Drain - Sanitary		30

Type	Qualifier	Distance
Building Overhang		3
Sewer - Building Sanitary		30
Septic or Holding, or POWTS Tank		42

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: