

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CN981		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner DAVID DESANTAS						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address R5754 ROBIN LN						Town of RINGLE							
City RINGLE						State WI		Zip Code 54471					
County Marathon		Co. Permit #		Notification #		Completed 12-26-1990		Street Address or Road Name and Number RIVER RD					
Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) DILLENBURG DANIEL				Lic. # 196		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address RT 3 BOX 247 SHAWANO WI 54166				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE SW Section Township Range or Govt Lot # 18 28 N 9 E					
Hicap Permanent Well #				Common Well #		Specific Capacity 0.9		2. Well Type New Well of previous unique well # constructed in 90					
Reason for replaced or reconstructed well ?													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
9 Surface 40			Yes Rotary - Mud Circulation Yes Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
6 40 85													
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
S G			SAND @ GRAVEL						Surface 22				
C G			CLAY @ STONE						22 40				
S Q			SOFT GRANITE						40 85				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)							
6		ASTM A53 18.97 SAWHILL WELDED				Surface 40							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)							
7. Grout or Other Sealing Material													
Method CIRCULATION													
Kind of Sealing Material				From (ft.) To (ft.) # Sacks Cement									
DRILLING MUD				Surface 40									
9. Static Water Level													
22 ft. below ground surface													
10. Pump Test													
Pumping level 38 ft. below surface Pumping at 15 GP for 2 Hrs. Pumping Method ?													
11. Well Is													
20 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
DD				Lic #		Date Signed 10-01-1990							
Drill Rig Operator				Lic or Reg #		Date Signed 10-01-1990							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		11

Comment:

Created On: 03-25-1991

Updated On: 03-25-1991

Review Status: