

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CO275		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner DAVE RITTER						Phone # (608)783-1869		1. Well Location				Fire # (if avail.)					
Mailing Address 638 11TH AVE N						Town of ONALASKA						Street Address or Road Name and Number APPLE BLOSSOM TRL					
City ONALASKA				State WI		Zip Code 54636											
County La Crosse		Co. Permit # W05739		Notification #		Completed 06-04-1992		Subdivision Name APPLE VALLEY				Lot # 00006		Block #			
Well Constructor (Business Name) OINES, ROY E				Lic. # 280		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address 406 WALNUT DR HOLMEN WI 54636-9605				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 20 17 N 7 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? WATER SUPPLY									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		Construction Type Drilled											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.5		Surface		90		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		S SAND Surface 30 N SAND STONE 30 65 H SHALE 65 85 N SANDSTONE 85 208		30 65 85 208							
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		120 ft. below ground surface				14 in. above grade			
6		NEW BLACK P.E. STEEL-WELD 18.97# .280 WALL ASTMA-53 SAWHILL				Surface		90		10. Pump Test Pumping level 140 ft. below surface Pumping at 10 GP for 3 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?											
Method TREMIE																	
Kind of Sealing Material		From (ft.)		To (ft.)								# Sacks Cement					
CEMENT		Surface		90		11		13. Constructor / Supervisory Driller									
Lic #		Date Signed															
RO		06-04-1992															
Drill Rig Operator		Date Signed															
Lic or Reg #		Date Signed															
RO		06-04-1992															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Foundation Drain to Clearwater		11
Building Drain - Sanitary		20	Sewer - Building Sanitary		35
Building Overhang		10	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: