

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CO300		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner JAMES ALME						Phone # (608)873-9044		1. Well Location				Fire # (if avail.)					
Mailing Address 2162 FALLEN OAK TRL						Town of PLEASANT SPRINGS											
City STOUGHTON						State WI		Zip Code 53589									
County Dane		Co. Permit # W05351		Notification #		Completed 04-02-1992		Subdivision Name				Lot # 00003					
Well Constructor (Business Name) VOGEL, ALBIN				Lic. # 634		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.01227 °N -89.22929 °W				Method Code GPS008					
Address RT 1 JEFFERSON WI 53549-9801				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 5 6 N 11 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? LANDSCAPE CONTRACTOR									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 2													
3. Well serves # of LANDSCAPE CONT Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology							
8		Surface		43		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 8in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		43		180				C		CLAY		Surface		22			
								L		LIME ROCK		22		92			
								N		SAND ROCK		92		180			
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level		11. Well Is					
6		NEW STEEL PLAIN END WITH WELDED JOINTS WT. 18.97LBS PER FOOT ASTM A-53 US MADE BY SAWHILL				Surface		43		38 ft. below ground surface		14 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test		Developed ? Yes Disinfected ? Yes Capped ? Yes					
										Pumping level 44 ft. below surface Pumping at 12 GP for 4 Hrs. Pumping Method ?							
7. Grout or Other Sealing Material																	
Method																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
PRESSURED CEMENT GROUT				Surface		43		14		NONE IN AREA							
13. Constructor / Supervisory Driller																	
AV				Lic #		Date Signed		04-06-1992									
Drill Rig Operator				Lic or Reg #		Date Signed		04-06-1992									
AV																	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment:

Created On: 05-21-1992

Updated On: 08-19-2022

Review Status: