Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CO300

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JAMES ALME			Phone #: (608)873-9044
Mailing Address: 2162 FALLEN OAK TRL			
City: STOUGHTON	State: WI	Zip Code: 53589	
County: Dane	Co. Permit #: W05351	Notification #	Completed: 04-02-1992

1. Well Location

Town of PLEASANT SPRINGS

Fire # (if avail.)

Street Address or Road Name and Number: 2891 MN.

Subdivision Name	Lot #	Block #
	00003	

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
VOGEL, ALBIN	634	

Latitude / Longitude in Decimal Degree (DD): 43.01227 °N -89.22929 °W

Method Code: GPS008

Well Plan Approval #

NW	SW	Section	Township	Range
or Govt Lot #		5	6 N	11 E

Address: RT 1
JEFFERSON WI 53549-9801

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		2

Reason for replaced or reconstructed well ?

LANDSCAPE CONTRACTOR

3. Well serves # of LANDSCAPE CONT

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	43
6	43	180

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....

Yes Temp. Outer Casing 8in. dia

Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	22
L	LIME ROCK	22	92
N	SAND ROCK	92	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL PLAIN END WITH WELDED JOINTS WT. 18.97LBS PER FOOT ASTM A-53 US MADE BY SAWHILL	Surface	43
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

38 ft. below ground surface

10. Pump Test

Pumping level 44 ft. below surface

Pumping at 12 GP for 4 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PRESSURED CEMENT GROUT	Surface	43	14

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE IN AREA

13. Constructor / Supervisory Driller	Lic #	Date Signed
AV		04-06-1992
Drill Rig Operator	Lic or Reg #	Date Signed
AV		04-06-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment:

Created On: 05-21-1992 Updated On: 08-19-2022 Review Status: