

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CO864		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner ELSIE STALKER						Phone # (608)296-3559		1. Well Location				Fire # (if avail.)	
Mailing Address RT 2 BOX 289						Town of SPRINGFIELD							
City WESTFIELD						State WI		Zip Code 53964					
County Marquette		Co. Permit #		Notification #		Completed 01-03-1992		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) DAVIS, FLOYD				Lic. # 678		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address RT 3 BOX 644 MONTELLO WI 53949-9378				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW SW Section Township Range or Govt Lot # 9 17 N 8 E					
Hicap Permanent Well #		Common Well #		Specific Capacity 6.7		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? NOT ENOUGH WATER							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
4		Surface		92									
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 4in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
A G S		SAND				Surface		86					
A G S		COARSE GRAVEL @ SAND				86		92					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
4		IN NEW BLK. STEEL T@C 11# PER FT. ASTM A53 2210PSI USP CO.				Surface		88					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
4		STAINLESS STEEL				88		92					
7. Grout or Other Sealing Material Method													
9. Static Water Level 34 ft. below ground surface													
10. Pump Test Pumping level 37 ft. below surface Pumping at 20 GP for 1 Hrs. Pumping Method ?													
11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No UP TO OWNER													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
Drill Rig Operator						Lic or Reg #		Date Signed					
FD								04-14-1992					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		72	Sewer - Building Sanitary		12
Building Overhang		5	Septic or Holding, or POWTS Tank		55

Comment:

Created On: 06-09-1992

Updated On: 06-09-1992

Review Status: