Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CO864

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ELSIE STALKER	Phone #: (608)296-3559
Mailing Address: RT 2 BOX 289	
City: WESTFIELD	State: WI — Zip Code: 53964
County: Marquette	Co. Permit #: — Notification #: — Completed: 01-03-1992
Well Constructor (Business Name): DAVIS, FLOYD	Lic. #: 678 — Facility ID # (Public Wells):
Address: RT 3 BOX 644 MONTELLO WI 53949-9378	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 6.7

1. Well Location

Town of SPRINGFIELD

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW	SW	Section	Township	Range
or Govt Lot #		9	17 N	8 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

NOT ENOUGH WATER

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	92

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	86
	A	G	S	COARSE GRAVEL @ SAND	86	92

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	IN NEW BLK. STEEL T@C 11# PER FT. ASTM A53 2210PSI USP CO.	Surface	88
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL	88	92

7. Grout or Other Sealing Material

Method

9. Static Water Level

34 ft. below ground surface

10. Pump Test

Pumping level 37 ft. below surface

Pumping at 20 GP for 1 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

UP TO OWNER

13. Constructor / Supervisory Driller	Lic #	Date Signed
Drill Rig Operator	Lic or Reg #	Date Signed
FD		04-14-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		72	Sewer - Building Sanitary		12
Building Overhang		5	Septic or Holding, or POWTS Tank		55

Comment:

Created On: 06-09-1992 Updated On: 06-09-1992 Review Status: