Well Construction Report
WISCONSIN UNIQUE WELL NUMBER CP763

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KENNETH KAKAC	Phone #: (715)327-4593
Mailing Address: 21961 SPIRIT LK RD W	
City: FREDERIC	State: WI — Zip Code: 54837
County: Burnett	Co. Permit #: — Notification #: — Completed: 04-28-1992
Well Constructor (Business Name): SULLIVAN, LYLE C	Lic. #: 120 — Facility ID # (Public Wells):
Address: RT 2 BOX 235 FREDERIC WI 54837-9593	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 2

1. Well Location

Town of TRADE LAKE

Fire # (if avail.):

Street Address or Road Name and Number: SPIRIT LAKE RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NE NW or Govt Lot #: — Section: 11 — Township: 37 N — Range: 18 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: PLANS TO STILL USE OTHER

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	20
4	20	211

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 7in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 8in. dia
- No — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	18
G	GRAVEL	18	197
S	SAND	197	211

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	USA STEEL ASTM A53 WELDED JONTS WT THICKNESS 10.79237.0	Surface	107
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL	107	111

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

9. Static Water Level

14 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 12 GP for _____ Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

PLANS TO STILL USE

13. Constructor / Supervisory Driller	Lic #	Date Signed
LS		05-24-1992
Drill Rig Operator	Lic or Reg #	Date Signed
LS		05-24-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		40
Building Overhang		8

Type	Qualifier	Distance
Shoreline/Pool		100
Septic or Holding, or POWTS Tank		80

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: