

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				CQ775		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner ANTHONY WRENSCH						Phone # () 788-6368		1. Well Location				Fire # (if avail.)											
Mailing Address W4117 CT M						Town of GREENFIELD						W4117											
City COON VALLEY						State WI		Zip Code 54623				Street Address or Road Name and Number											
City COON VALLEY						State WI		Zip Code 54623				CTH M											
County La Crosse		Co. Permit # W03773		Notification #		Completed 01-10-1991		Subdivision Name				Lot #											
Subdivision Name		Lot #		Block #																			
Well Constructor (Business Name)				Lic. # 252		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)													
HOLLER NORMAN				252		43.7497 °N -91.1111 °W				Method Code GCD013													
Address 4049 STATE RD LA CROSSE WI 54601				Well Plan Approval #		NE NE		Section 29		Township 15 N		Range 6 W											
Address 4049 STATE RD LA CROSSE WI 54601				Approval Date (mm-dd-yyyy)		or Govt Lot #		29		15 N		6 W											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4				2. Well Type New Well													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4				of previous unique well #													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4				Reason for replaced or reconstructed well ?													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4				WATER													
3. Well serves 1 # of				Hicap Well ? No		Construction Type Drilled																	
Private, potable				Hicap Property ? No																			
Heat Exchange ___ # of drillholes				Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		63		Rotary - Mud Circulation						C		CLAY		Surface		31					
6		63		110		Rotary - Air						H		SHALE		31		43					
						Rotary - Air & Foam						N		SAND ROCK		43		110					
						Drill-Through Casing Hammer																	
						Reverse Rotary																	
						Cable-tool Bit 10in. dia...																	
						Dual Rotary																	
						Temp. Outer Casing ___ in. dia																	
						Removed? ___ depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		63 ft. below ground surface				15 in. above grade									
6		BLACK PLAIN-END VENEZULA .280 18.97 P/E ASTM A53				Surface		65		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 91 ft. below surface				Disinfected ? Yes									
										Pumping at 10 GP for 8 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method C PUMP														Filled & Sealed Well(s) as needed?									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed							
CEMENT				Surface		63		7		NH						01-16-1991							
										Drill Rig Operator				Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Sewer - Building Sanitary		33
Nonconforming Pit or Alcove		164	Septic or Holding, or POWTS Tank		7

Comment:

Created On: 04-03-1991

Updated On: 04-30-2020

Review Status: